

GAS SAFETY INSPECTION

Boat Name: ADVENTURING LIGHT 1

Printed Name: PHILIP MONSEY

Registration No: 883Y

Licence No: 4612145

NEXT SAFETY CHECK DUE WITHIN 12 MONTHS

Date: 17/01/2022

APPLIANCE DETAILS					INSPECTION DETAILS		
LOCATION	TYPE	MAKE	FLUE TYPE	Working Pressure	VENTILATION CORRECT/ CLEAR YES/NO	SAFETY DEVICES OPERATING YES/NO	APPLIANCE SAFE TO USE YES/NO
GALLEY	HOB	CAN	UF	37	YES	YES	YES
GALLEY	COOKER	THETFORD DUPLEX	UF	37	YES	YES	YES
Work carried out : <u>GAS SAFE TEST</u>							
EMERGENCY CONTROLS			PASS	CYLINDER STORAGE		PASS	
Is the emergency control correctly positioned/ accessible			✓	Cylinder Compartment Construction		✓	
Is the emergency control labelled			✓	Cylinder Compartment Vent		✓	

TEST	PASS	mb	BUTANE	PROPANE	TEST GUIDANCE
Installation Test [Air]	N/A	N/A	45 mb	45 mb	45 mb for 5 min > 2 min test
Soundness [High]	N/A	LDF	N/A	N/A	N/A
Regulator Lock-up	✓	43	40mb max	50mb max	No increase after 60 secs
Let by ECV	✓	15	5 mb	5 mb	5 mb for 5 min > 2 min test
Soundness [Low]	✓	30	28/29 mb	37 mb	Lockup for 5min > 2min @ 28/37 mb
Burner Press Max	✓	41	35mb	46 mb	
Burner Press Min	✓	40	20mb	25 mb	

SIGNED: Philip Monsey